

Table 2. Water sample UV fiber counts.

	Sample Number	Description	Volume of Water Sample Filtered			
			500ml	500 ml	250 ml	250 ml
<b>Hot Water Tank</b>						
	006.1	Hot Water Tank	>50	>50	>25	>25
<b>Before Tank Removal</b>						
	006.2	Shower/Hot water	1	3	2	5
	118.1	Shower/Hot water	3	7	7	6
	006.3	Kitchen/Cold water	NT	NT	0	0
<b>After Tank Removal</b>						
	118.3	Shower/Hot water	11	11	10	4
	338.1A	Shower/Hot water	17	>50	46	33
	118.2	Kitchen/Hot water	0	3	3	1
	118.4	Kitchen/Cold water	0	NT	2	0
<b>During Pipe Replacement</b>						
	338.1	Shower/Hot water	5	5	2	3
	338.7	Kitchen/Hot water	2	2	0	0
	338.8	Kitchen/Cold water	1	1	0	0
<b>After Pipe Replacement</b>						
	388.1	Shower/Hot water	0	0	1	1
	338.3	Tub Faucet/Hot water	1	1	1	0
	338.4	Tub Faucet/Cold water	1	0	0	0
	388.2	Kitchen/Hot water	1	2	1	1
	388.3	Kitchen/Cold water	1	1	1	2

NT not tested